




# GROUP F

○ STATES FOAM IS ON NEAR SIDE  
○ STATES FOAM IS ON FAR SIDE

## RADIATOR INSULATION DETAIL



TYPICAL INSTALLATION OF ROOFTOP INSULATION ONLY



**EXPLODED VIEW: EV ENCLOSURE C2****DRAWING #:10000016678****GROUP F**

| ITEM  | PART#        | QTY. | DESCRIPTION                                  |
|-------|--------------|------|----------------------------------------------|
| 1     | 0E5968       | 1    | GASKET, EXTRUDED TRIM (448.0"LG)             |
| 2     | 10000015205  | 1    | AL13 FRONT LEFT CORNER C2                    |
| 3     | 0K3689       | 1    | FRONT DIVIDER C2                             |
| 4     | 10000017409  | 1    | AL13 EXTERNAL VENT COVER PLATE BISQUE        |
| 5     | 10000018613  | 1    | CUSTOMER ACCESS ASSEMBLY                     |
| 6     | 10000015223  | 1    | AL13 VENTING ROOF C2                         |
| 7     | 0K4322       | 1    | EYE HASP CUST ACCESS BOX                     |
| 8     | G022473      | 1    | WASHER FLAT 1/4-M6 ZINC                      |
| 9     | 0K2679       | 1    | INSUL DUCT C2 D3.4L                          |
| 10    | G066760      | 1    | STRIP SEALANT 1/8 X 1                        |
| 11    | 10000004886  | 1    | AL13 PANEL REAR LEFT C2 CPL                  |
| 12    | 10000015214  | 1    | AL13 FRONT DOOR C2                           |
| 13    | G022097      | 1    | WASHER LOCK M6-1/4                           |
| 14    | 10000004847  | 1    | AL13 SIDE DOOR RIGHT C2 CPL                  |
| (1)15 | 0C2454       | 35   | SCREW HWHT M6-1 X 16 N WA Z/JS               |
| (1)16 | 0E3257       | 18   | SCREW HWHTF M6-1.0 X 16                      |
| 17    | 0K37870AL13  | 1    | PANEL CENTER REAR C2 CPL_                    |
| 18    | 0C2634A      | 1    | ASSY ACCESS COVER                            |
| 19    | G022127      | 1    | NUT HEX 1/4-20 STEEL                         |
| 20    | 0K2671       | 2    | INSUL DOOR C2 D3.4L                          |
| 21    | 0F5048D      | 3    | WISE-ACTION LATCH, SLOTTED CIR               |
| 22    | 0K2671B      | 2    | INSUL CORNER POST C2 D3.4L                   |
| 23    | 0F5049B      | 3    | PULL TAB DOOR LOCK ST                        |
| 24    | 0K2671A      | 1    | INSUL ROOF TOP C2 D3.4L                      |
| 25    | 0F8869D      | 1    | KEY WISE-ACTION LATCH SLOT CIR               |
| 26    | 0K2671E      | 4    | INSUL ROOF SIDES C2 CPL                      |
| 27    | 10000015202  | 1    | AL13 ROOF C2 (FOR 30KW UNITS ONLY)           |
| 28    | 0J7751       | 4    | SCREW PPHTF #10-16 X 1/2 B                   |
| 29    | 10000004848  | 1    | AL13 PANEL REAR RIGHT C2 CPL                 |
| 30    | 0K2671C      | 1    | INSUL FRONT C2 D3.4L                         |
| 31    | 10000015215  | 1    | AL13 FRONT RIGHT CORNER C2                   |
| 32    | 078115A      | 6    | WASHER SELF LOCKING DOME #8-32               |
| 33    | 0D3700       | 10   | NUT FLANGE M6-1.0 NYLOK                      |
| 34    | 0K8641       | 9    | SCREW HHFC M6-1.0 X 20 NYL WA                |
| 35    | G080318      | 2    | SCREW HHFC M6-1.0 X 25 FTH G8                |
| 36    | G077992      | 32   | NUT HEX LOCK M6-1.0 SS NY INS                |
| 37    | 10000004849  | 1    | AL13 SIDE DOOR LEFT C2 CPL                   |
| 38    | 100000018715 | 1    | AL13 ROOF C2 BISQUE (FOR 48-50KW UNITS ONLY) |
| 39    | 10000016218  | 2    | SWITCH ROCKER SPST ON-OFF IP65               |
| 40    | 10000036562  | 2    | INSUL SLVR MLR 111x871 BLOCKOFF SIDE RAIL    |

## NOTES (UNLESS OTHERWISE SPECIFIED):

- (1) ENCLOSURE NOTE: PANELS THAT FASTEN TO THE BASEFRAME MUST BE SECURED USING I/N 15 & 16 (THREAD FORMING FASTENERS). ALL PANEL TO PANEL CONNECTIONS TO INCLUDE AT LEAST ONE CONNECTION POINT USING I/N 16 (THREAD FORMING FASTENER).