
# GROUP F







EXPLODED VIEW:
ENCLOSURE C1 CPL
DRAWING #: 0F7356

REVISION: G-7989-C
DATE: 4/25/06

# EXPLODED VIEW: ENCLOSURE C1 CPL
# DRAWING #: 0F7356

## GROUP F

APPLICABLE TO:

| ITEM | PART # | QTY. | DESCRIPTION |
|---|---|---|---|
| 1 | 0F7003 (XX) | 1 | ROOF C1 CPL |
| 2 | 0F7004 (XX) | 1 | CORNER POST LH SIDE C1 CPL |
| 3 | 0F7008 (XX) | 1 | DOOR REAR C1 CPL |
| 4 | 0F7005 (XX) | 1 | CORNER POST RH SIDE C1 CPL |
| 5 | 0F7007 (XX) | 2 | DOOR LH & RH SIDE C1 CPL |
| 6 | 0F7006 (XX) | 1 | DUCT FRONT DISCHARGE C1 CPL |
| 7 | 0C2634A | 1 | ASSEMBLY COVER ACCESS |
| 8 | 0912970091 | 1 | ASSY WIRE 14AWG 13.8" GRN/YEL |
| 9 | 0912970090 | 2 | ASSY WIRE 14AWG 33.5" GRN/YEL |
| 10 | 0E5968 | 1 | GASKET EXTRUDED TRIM (356" LG) |
| 11 | 0E3257 | 6 | SCREW HWHTF M6-1.0 X 16 |
| 12 ** | 077992 | 18 | NUT HEX LOCK M6-1.0 SS NY INS |
| 13 | 0F5049 | 3 | TAB PULL |
| 14 | 0F5048D | 3 | VISE-ACTION LATCH SLOTTED CIR |
| 15 | 022473 | 1 | WASHER FLAT 1/4-M6 ZINC |
| 16 | 022097 | 1 | WASHER LOCK M6-1/4 |
| 17 | 022127 | 1 | NUT HEX 1/4-20 STEEL |
| 18 | 0C2454 | 24 | SCREW THF M6-1 X 16 N WA Z/JS |
| 19 | 078115 | 20 | WASHER SELF LOCKING DOME |
| 20 | 0F3890B | 2 | RETAINER INSULATION (820) |
| 21 | 0F3890 | 4 | RETAINER INSULATION (450) |
| 22 | 0F7365 | 2 | INSULATION SIDE DOOR C1 |
| 23 | 0F7365B | 1 | INSULATION REAR DOOR C1 CPL |
| 24 | 0F7365A | 1 | INSULATION ROOF C1 CPL |
| 25 | 0F8869D | 1 | KEY VISE-ACTION LATCH SLOT CIR |

OPTIONAL COMPARTMENT MATERIALS:
ALL P/N'S WITH AN (XX) SUFFIX INDICATE A MULTIPLE MATERIAL AND COLOR OPTION.
USE THE FOLLOWING LEGEND TO IDENTIFY THE CORRECT PART NUMBER:

| PART NO. | MATERIAL | COLOR |
|---|---|---|
| 0XXXXXSN | STEEL | TAN |
| 0XXXXXAN | ALUMINUM | TAN |
| 0XXXXXSG | STEEL | GRAY |
| 0XXXXXAG | ALUMINUM | GRAY |

** ALUMINUM ENCLOSURE NOTE: ALL ENCLOSURE PANELS THAT FASTEN TO THE BASE FRAME MUST BE SECURED USING ITEM 18 & 11 THREAD FORMING FASTENER AND ITEM 12 LOCK NUT. LOCK NUT IS TO BE INSTALLED AFTER THREAD FORMING FASTENER HAS PENETRATED THROUGH EXTRUSIONS IN ENCLOSURE PANELS. ALL ROOF PANELS ARE TO BE SECURED IN THE SAME MANNER.