

PROTECTOR DIESEL

PRE-ORDER CHECKLIST / CODE DRIVEN ACCESSORY LIST

- ☐ The local fire marshal has confirmed that the generator must be located a minimum of _____ feet from a house or other structure.
NOTE: Generac recommends a minimum clearance of five feet.
- ☐ The local Authority Having Jurisdiction (AHJ) has advised me regarding the requirements for electrical and/or building permits, as well as those regulations relating to emissions and fuel storage.
- ☐ I have been advised of the local requirements for construction of a concrete base pad, and whether anchoring requirements are needed for installation on a flood plain.
- ☐ I have confirmed with the appropriate authorities that the generator must be located a minimum of _____ feet from a property line.
- ☐ I have been advised whether the local fire marshal (or other third party) is required to be present at start up.
- ☐ I have confirmed that the installation site is applicable to optional standby only and does not require an NFPA 110 capable generator.
- ☐ The local fire marshal has confirmed that I am required to extend the fuel tank vents _____ feet above the surrounding grade.
- ☐ The local fire marshal has confirmed that local codes require installation of the diesel product safety accessories designated below.

Item	Description	Part Number	Required
	Emergency Stop Switch	006510-0	☐ YES ☐ NO
	90% Fuel Level Alarm	006504-0	☐ YES ☐ NO

Item	Description	Part Number	Required
	Five Gallon Spill Box	006502-0	☐ YES ☐ NO
	Spill Box Drain Back	006511-0	☐ YES ☐ NO
	Anti-Static Fuel Fill Tube	006507-0	☐ YES ☐ NO
	Fuel Tank Support Risers	006505-0 (15 & 20 kW) 006506-0 (30 & 50 kW)	☐ YES ☐ NO ☐ YES ☐ NO
	Stainless Steel Fuel Lines	006513-0 (15 & 20 kW) 006517-0 (30 kW) 006516-0 (50 kW)	☐ YES ☐ NO ☐ YES ☐ NO ☐ YES ☐ NO
	Vent Extension Support Kit	006588-0	☐ YES ☐ NO
	Lockable Cap	006512-0	☐ YES ☐ NO