

☐ STATES FOAM IS ON NEAR SIDE

☐ STATES FOAM IS ON FAR SIDE



EXPLODED VIEW: ENCLOSURE 4.2L G3 TELECOM
DRAWING #: 0G6959

GROUP F

APPLICABLE TO:

ITEM	PART #	QTY.	DESCRIPTION
1	0G46640AL08	1	DUCT AIR REAR TOP
2	0C2454	55	SCREW THF M6-1 X 16 N WA Z/JS
3	0F5849AG	2	DOOR C2 ALUM GRAY
(1) 4	077992	5	NUT HEX LOCK M6-1.0 SS NY INS
5	0F3890A	6	RETAINER INSULATION (740)
6	0F6647	2	DISCHARGE DUCT L/H & R/H SIDE
7	0F6642	2	FRONT CORNERS
8	0F6650	1	DISCHARGE DUCT MIDDLE
9	051716	2	NUT HEX M5-0.8 G8 CLEAR ZINC
10	022769	2	WASHER SHAKEPROOF INT #10
11	0F6644	1	ROOF
12	0E5968	1	GASKET EXTRUDED TRIM (158.50" LG)
13	0F5048D	2	WISE-ACTION LATCH SLOTTED CIR
14	022127	1	NUT HEX 1/4-20 STEEL
15	022097	1	WASHER LOCK M6-1/4
16	0F5049	2	TAB PULL
17	0C2634A	1	ASSEMBLY COVER ACCESS
18	051713	2	WASHER FLAT M5
19	052619	2	SCREW HHC M5-0.8 X 20 G8.8
20	0912970100	2	ASSY WIRE 14AWG 48.0" GRN/YLW
21	0G6953G	2	INSUL, SIDE SUPPORT
22	078115	12	WASHER SELF LOCKING DOME
23	0G45170AL08	1	DUCT AIR REAR WRAP
24	0G5892A	1	INSULATION ROOF TOP
25	089961	2	FOAM STRIP 3/4" WIDE X 3/16" THK (144" LG)
26	029289	4	TAPE ELEC 1/2 FOAM (40" LG)
27	029289	2	TAPE ELEC 1/2 FOAM (8" LG)
28	029289	1	TAPE ELEC 1/2 FOAM (33.187" LG)
29	0G45130AL08	1	BAFFLE AIR ANGULAR
30	0F8869D	1	KEY WISE-ACTION LATCH SLOT CIR
31	049226	2	WASHER LOCK M5
32	022473	1	WASHER FLAT 1/4-M6 ZINC
33	0G45200ST03	1	COVER BASE REAR
(2) 34	0G3746	4	PLUG DOME 2.5" BLACK
35	0G45140AL08	1	BAFFLE AIR VERTICAL
36	0G45150AL08	1	CORNER POST LH REAR
37	0G45160AL08	1	CORNER POST RH REAR
38	0G45180AL08	1	BRACE TOP REAR
39	0G45190AL08	1	BLOCK OFF BOTTOM REAR
40	029289	2	TAPE ELEC 1/2 FOAM (11" LG)
41	029289	1	TAPE ELEC 1/2 FOAM (32" LG)
42	0G6953A	1	INSUL, FRONT WRAP
43	0G6953B	1	INSUL, FRONT ROOF
44	0G6953C	1	INSUL, REAR DUCT
45	0G6953D	1	INSUL, TOP DUCT
46	0G6953E	2	INSUL, REAR SIDE DUCT
47	0G6953F	2	INSUL, SIDE DUCT
48	0G6953H	1	INSUL, INSIDE BAFFLE
49	0G5892	2	INSULATION DOOR C2
50	0C9724	A/R	CAULK CLIMACEL CLEAR
51	0E5298L	1	FOAM 300 X 300 THERMAL ACO

(1) ALUMINUM ENCLOSURE NOTE: ALL ENCLOSURE PANELS THAT FASTEN TO THE BASE FRAME MUST BE SECURED USING ITEM 2, THREAD FORMING FASTENER AND ITEM 4 LOCK NUT. LOCK NUT IS TO BE INSTALLED AFTER THREAD FORMING FASTENER HAS PENETRATED THROUGH EXTRUSIONS IN ENCLOSURE PANELS.

(2) ITEM 34 (PLUG DOME 2.5" BLACK) IS USED AFTER SHIPPING. HOLES ARE TO REMAIN UNCOVERED FOR SHIPPING PURPOSES. PLUGS CAN BE FOUND IN THE MANUAL BAG.

(3) CAULK CORNERS FROM INSIDE BEFORE ASSEMBLY.

(4) CAULK SEAM AFTER ASSEMBLY.

SPECIAL NOTE: LEAVE ALL ENCLOSURE FASTENERS LOOSE UNTIL DOORS ARE FITTED. AFTER DOOR FIT IS ACHIEVED TIGHTEN ALL FASTENERS.