



0H8536

WIRING-DIAGRAM



WIRING-DIAGRAM



LEGEND
 AVR - AUTOMATIC VOLTAGE REGULATOR
 BA - BRUSH ASSEMBLY
 CI - 2 POLE FREE HANDLING CONNECTOR, PLUS TO CAP
 CE - 4 POLE AVR TO ALTERNATOR CONNECTOR, CAP TO PLUS
 GND - GROUND STUD
 HM - HOUR METER
 ICT - ILE CONTROL TRANSFORMER
 IN - IGNITION NEEDLE
 LOP - LOW OIL PRESSURE SWITCH
 NEUT - NEUTRAL STUD
 SP - SPARK PLUG
 SV1 - VOLTAGE SELECTOR SWITCH, 180V/240V, 30A, 3PDT
 SVE - RUN-STOP SWITCH
 SVS - ILE CONTROL SWITCH
 TB - ALTERNATOR TERMINAL BLOCK
 □ - INTERCONNECT

SHEET 1 OF 2

GENERAC POWER SYSTEMS OWNS THE COPYRIGHT OF THIS DRAWING WHICH IS SUPPLIED IN CONFIDENCE AND MUST NOT BE USED FOR ANY PURPOSE OTHER THAN FOR WHICH IT IS SUPPLIED WITHOUT THE EXPRESS WRITTEN CONSENT OF GENERAC POWER SYSTEMS.

© GENERAC POWER SYSTEMS 888

EST. WT.

FINAL WT.

DO NOT SCALE

ALL DIMENSIONS AND TOLERANCING PER ASME Y14.5M-1994
 UNLESS OTHERWISE SPECIFIED:
 ALL XX DIM — 0.4 MM
 ALL XXJ DIM — 0.4 MM
 ALL XXJX DIM — 0.15 MM
 ALL ANGLES — 31°

DRAWING TITLE

WIRING DIAGRAM/SCHEMATIC,
 XP4000 PORT, GFCI

MATERIAL

N/A

DWN

GMP

DATE

04/13/10

MFG

DATE

10/19/10

CHKD

KC

DATE

10/18/10

APPD

KB

DATE

10/19/10

RELEASED FOR PRODUCTION

BY

KBAUER

GENERAC POWER SYSTEMS
Whitewater

P.O. BOX 8
 WAUKESHA, WIS. 53187

FILE NAME

0H8536-D.DWG

SIZE B

SCALE

1 = 1

FIRST USE

5929-0

DWG NO.

0H8536

REV

D

10/19/10

-A-

RELEASED

10/26/10

H-7714-B

WIRE LABELED "WHT" FROM GFCI WAS CONNECTED TO A DUPLEX OUTLET NEUTRAL TERMINAL.

12/30/10

H-8023-C

ADDED A 30A/250V C.B. FOR EACH DUPLEX OUTLET, REROUTED WIRING CONNECTIONS OF DUPLEX OUTLETS AND HM TO 30A/250V OUTLETS AND C.B.

05/20/11

H-8850-D

SHEET 2 - MODIFIED SCHEMATIC DRAWING TO SHOW CORRECT AVR VOLTAGE SENSING CONNECTIONS TO THE STATOR WIRING.

