

0H1272

NOTE: ALL RECEPTACLES SHOWN AS VIEWED FROM REAR [WIRE SIDE]

UNIT RATING	2 POLE BREAKER RATING
5.0kV	21
5.5kV	23
6.5kV	27
7.0kV	30

LEGEND:

- A - RECEPTACLE #1 [120VAC 20A NEMA 5-20R GFCI]
- B1 - 20AMP CIRCUIT BREAKER #1
- B2 - 20AMP CIRCUIT BREAKER #2
- C - RECEPTACLE #2 [120VAC 20A NEMA 5-20R GFCI]
- D - CIRCUIT BREAKER [SEE TABLE]
- E - RECEPTACLE #3 [120/240VAC 30A NEMA L14-30R]
- F - HOUR METER [IF EQUIPED]
- G - ALTERNATOR SECTION
- H - PRIMARY WINDING
- I - PRIMARY WINDING
- J - EXCITATION WINDING
- K - AUTOMATIC VOLTAGE REGULATOR
- L - ENGINE SECTION
- M - SPARK PLUG
- N - IGNITION COIL
- O - LOW OIL LEVEL SWITCH
- P - LOW OIL LEVEL ALARM
- Q - ENGINE RUN/STOP SWITCH
- R - CHASSIS GROUND
- S - ROTOR WINDING
- T - BRUSH ASSEMBLY
- U - NEUTRAL POST

10/30/09	- A -	RELEASE FOR PRODUCTION.						

GENERIC POWER SYSTEMS OWNS THE COPYRIGHT OF THIS DRAWING WHICH IS SUPPLIED IN CONFIDENCE AND MUST NOT BE USED FOR ANY PURPOSE OTHER THAN FOR WHICH IT IS SUPPLIED WITHOUT THE EXPRESS WRITTEN CONSENT OF GENERIC POWER SYSTEMS.

© GENERIC POWER SYSTEMS 2001

EST. WT.	
FINAL WT.	
DO NOT SCALE	
ALL DIMENSIONS AND TOLERANCING PER ASME Y14.5M-1994	
UNLESS OTHERWISE SPECIFIED :	
ALL XX DIM	±0.4 MM
ALL XX DIM	±0.4 MM
ALL XXXX DIM	±0.15 MM
ALL ANGLES	±1°

DRAWING TITLE			
WIRING DIAGRAM PORTABLE UP TO 7kW CA-GP			
MATERIAL			
DWN	DREW	DATE 10/30/08	MFG
CHKD	DMC	DATE 11/10/08	APP'D SS
RELEASED FOR PRODUCTION		BY SAEID SHOKRZADEH	DATE 11/10/08

GENERAC POWER SYSTEMS Whitewater P.O. BOX 8 WAUKESHA, WIS. 53187		SIZE
0H1272-A.DWG		
QUANTITY 1 = 1	FIRST USE	CA MODEL
0H1272		