0H6393

"10" & LATER HSB AIR-COOLED GENERATORS SINGLE & V-TWIN ENGINES

PRE "10" LOAD CENTER TRANSFER SWITCH



CONNECT WIRE #T1 FROM HSB TO FUSED (5A) LOAD SOURCE.

1) INSTALL KIT PART NO. 0G9254 ON ATS. ROUTE T1 WIRE (FUSED LOAD SUPPLY) IN 30 FT. CONDUIT TO EXT. CONNECTION BOX. CONNECT TO T1 WIRE FROM HSB OR,
2) ROUTE 120 VAC 15A CIRCUIT FROM GENERATOR PROTECTED PANELBOARD TO T1 IN THE GENERATOR CONTROL PANEL. NEUTRAL TO NEUTRAL TERMINAL.

PRE "10" HSB AIR-COOLED GENERATORS SINGLE & V-TWIN ENGINES

"10" & LATER LOAD CENTER TRANSFER SWITCH



03/18/10	"A"	RELEASED FOR PRODUCTION

DRAWING TITLE	INSTALLATION DRAWING, HOME STAND-BY
MATERIAL	N/A
DWN	GDW
DATE	03/18/10
MFG	N/A
DATE	N/A
CHKD	JJJ
DATE	03/18/10
APPD	MJB
DATE	03/18/10
RELEASED FOR PRODUCTION BY	J.JONAS
DATE	03/18/10
FILE NAME	0H6393-A.DWG
SIZE	D
SCALE	1 = 1
FIRST USE	2010HSB
DWG NO.	0H6393
REV	A

DO NOT SCALE

ALL DIMENSIONS AND TOLERANCING PER ASME Y14.5M-1994

UNLESS OTHERWISE SPECIFIED:

EST. WT.

FINAL WT.

GENERAC POWER SYSTEMS
Whitewater
P.O. BOX 8
WAUKESHA, WIS. 53187