


Bl	Black
O	Orange
Bu	Blue
Gr	Grey
R	Red
Br	Brown
Br/R	Brown/Red
LB	Light Blue
Bl	Black
W	White
Y/G	Yellow/Green
Bl/W	Black/White
G	Green

REVISIONS				
REV	ECO/ENG	DESCRIPTION	DATE	BY
0	0757/CGH	RELEASED	1/21/2014	JDY
A	CN-1361	RELEASED AT GENERAC	6/6/2016	NSK



- NOTES:
1. ALL RECEPTACLES TO BE CSA OR cUL APPROVED
 2. ALL CIRCUIT BREAKERS TO BE CSA OR cUL APPROVED
 3. WIRES TO BE CSA OR cUL APPROVED
 4. WIRES SHOULD BE INSULATED STRANDED COPPER WIRE RATED FOR 105° AND 600V
 5. WIRE GAUGE: AS MARKED, (FOR ALL WIRES IN CONTROL PANEL EXCEPT FOR HOUR METER AND ENGINE SWITCH)

GROUNDING SYSTEM: NEUTRAL BONDED TO FRAME


(A)

NOTICE

GENERAC POWER SYSTEMS, INC HAS GIVEN YOU USE OF THIS PRINT FOR THE PURPOSE OF PERMITTING YOU TO QUOTE ON OR FILL AN ORDER FOR US. IT IS YOUR DUTY TO KEEP THIS CONFIDENTIAL, AND NOT PERMIT DUPLICATION. THANK YOU

DO NOT SCALE

DIMENSIONS ARE IN INCHES UNLESS OTHERWISE SPECIFIED
TOL ON DECIMALS: .XX ± .03
TOL ON ANGLES: ± 1°



GENERAC®

DRAWN BY:

NSK

PROJ ENG:

BCD

P/N:

10000003699

DATE:

6/6/2016

SCALE:

1:1

3D CAD MODEL VERSION:

C

SIZE:

C

OLD PART NUMBER

SPM0141200

TITLE:

SCHEMATIC WX
1200

DWG NO.:

10000003699

REV

A

SHEET

1 OF 1