REVISIONS				
REV	ECO/ENG	DESCRIPTION	DATE	BY
0	0879/DAB	RELEASED	2/11/2015	LFL
A	CN-1361	RELEASED AT GENERAC	6/6/2016	NSK

Bl	Black
R	Red
W	White
GRN/YEL	Green/Yellow
Br	Brown
Bu	Blue
O	Orange
Bl/W	Black/White



NOTES:
1. ALL RECEPTACLES TO BE CSA OR cUL APPROVED
2. ALL CIRCUIT BREAKERS TO BE CSA OR cUL APPROVED
3. WIRES TO BE CSA OR cUL APPROVED
4. WIRES SHOULD BE INSULATED STRANDED COPPER WIRE RATED FOR 105° AND 600V
5. WIRE GAUGE: AS MARKED, (FOR ALL WIRES IN CONTROL PANEL EXCEPT FOR HOUR METER AND ENGINE SWITCH)

GROUNDING SYSTEM: NEUTRAL BONDED TO FRAME

Ⓐ

NOTICE

GENERAC POWER SYSTEMS, INC HAS GIVEN YOU USE OF THIS PRINT FOR THE PURPOSE OF PERMITTING YOU TO QUOTE ON OR FILL AN ORDER FOR US. IT IS YOUR DUTY TO KEEP THIS CONFIDENTIAL, AND NOT PERMIT DUPLICATION. THANK YOU

DO NOT SCALE

DIMENSIONS ARE IN INCHES UNLESS OTHERWISE SPECIFIED
TOL ON DECIMALS: .XX ± .03
.XXX ± .01
TOL ON ANGLES: ± 1°

THIRD ANGLE PROJECTION

GENERAC®

DRAWN BY:	PROJ ENG:	P/N:	
NSK	BCD	10000003709	
DATE: 6/6/2016	SCALE: 1:1	3D CAD MODEL VERSION:	SIZE: C

OLD PART NUMBER SPM0143400

TITLE: SCHEMATIC WX 3400

DWG NO.: 10000003709

REV A

SHEET 1 OF 1