



GROUP H





TA CONVENTIONAL

VIEW FROM REAR



NA CONVENTIONAL

VIEW FROM FRONT





NA COMPACT & TA COMPACT



VIEW FROM REAR

GROUP H




**TA CONVENTIONAL
10-25KW BRUSHED/BRUSHLESS
REPRESENTATION SHOWN IS 3PH**



**TA CONVENTIONAL
30KW AND UPSIZED
BRUSHED/BRUSHLESS
REPRESENTATION SHOWN IS 3PH**






NA CONVENTIONAL 1PH




NA CONVENTIONAL 3PH

GROUP H




NA COMPACT & TA COMPACT




PLACE DECAL 0C1229 ON OUTSIDE OF
REAR ENCLOSURE COVER PANEL

NA CONVENTIONAL



PLACE DECAL 0C1229 ON OUTSIDE OF
REAR ENCLOSURE COVER PANEL.
USE SAME LOCATION FOR OPEN SET.

TA CONVENTIONAL



PLACE DECAL 0C1229 ON LOWER COVER
PLATE BELOW CIRCUIT BREAKERS.
USE SAME LOCATION FOR OPEN SET.

EXPLODED VIEW: EV 5R CT MOUNTING KIT**DRAWING#: A0001464790****GROUP H**

ITEM	PART#	QTY.	DESCRIPTION
1	G047411	2 / 3	SCREW HHC M6-1.0 X 16 C8.8
2	0J7513	2 / 3	WASHER LOCK M6 CLEAR ZINC
3	0H7899	2 / 3	WASHER FLAT M6 X 18MM
4	0J1857	2 / 3	CT BRKT 1.1 WINDOW FRAME
5	0J0481	2 / 3	XFMR CURRENT 50A W/BRKT UL RCG
	0J0481A	2 / 3	XFMR CURRENT 100A W/O BRKT UL
	0J0481B	2 / 3	XFMR CURRENT 150A W/O BRKT UL
(4)6	0C1229	1	DECAL WARNING ELECTRICAL SHOCK

NOTES (UNLESS OTHERWISE SPECIFIED):

(1) QTY. REQ. FOR 1 PHASE / QTY. REQ. FOR 3 PHASE.

(2) POSITION SHOWN IS FOR PRIMARY CIRCUIT BREAKER.

(3) ZIPTIE EXCESS LEAD LENGTH TO EITHER LEFT OR RIGHT ALTERNATOR TIE ROD.

(4) SEE PAGE 4 FOR DECAL LOCATION FOR ALL UNITS.

ITEM	PART#	QTY.	DESCRIPTION
------	-------	------	-------------

This page left blank intentionally.